



The State of New Hampshire
Department of Environmental Services



Michael P. Nolin
Commissioner
January 13, 2004

Munces Superior Inc
ATTN: Rob Munce
620 Main Street
Gorham, NH 03581

**NOTICE OF NON-COMPLIANCE and
PERMIT REVOCATION – NCPR # 04-001**

RE NEW HAMPTON, NEW HAMPTON KWIK STOP, EXISTING UNDERGROUND STORAGE
TANK FACILITY (UST #A-0110674) (DES #199307024)

Dear Mr. Munce:

The New Hampshire Department of Environmental Services (“DES”) is hereby notifying you that the above-referenced facility, located at 325 Route 104, New Hampton, NH is not in compliance with New Hampshire Code of Administrative Rules Env-Wm 1401, regulating Underground Storage Facilities. On July 17, 2003 a DES inspector conducted a compliance audit at the facility. A written document, describing the deficiencies was provided to the facility representative. This document required the facility be returned to compliance within 45 days, and DES be notified of the corrective measures taken. Compliance has not been achieved. **Failure to achieve compliance with the following deficiencies within 90 days from the date of this Notice of Non-Compliance and Permit Revocation (“Notice”) will result in revocation of your Permit-to-Operate on April 12, 2004. This letter contains important compliance and procedural information. Please read it carefully.**

Env-Wm 1401.11 Inventory Monitoring

Env-Wm 1401.11 requires inventory monitoring be conducted and inventory records be maintained on motor fuel, hazardous substance and bulk heating oil systems without secondary containment and leak monitoring for both tank and piping. DES has determined that inventory monitoring was not being conducted correctly for the three 8,000-gallon gasoline and one 8,000-gallon diesel USTs. Inventory monitoring shall be corrected and one month of inventory monitoring results for the three gasoline and one diesel USTs shall be provided to DES.

2 Env-Wm 1401.30 Release Detection for Piping

Env-1401.30 requires records be maintained for line leak detector tests. The DES has determined that the passing annual line leak detector tests had not been performed since September 17, 1997 for two gasoline USTs and had never been performed for one gasoline UST and one diesel UST. A passing annual line leak detector test for 2003 for the three gasoline and one diesel USTs shall be provided the DES.

In addition, Env-Wm 1401.10(a) requires owners of underground storage facilities for oil to maintain financial responsibility for costs associated with cleanup of releases from systems, the implementation of corrective measures, and compensation for third party damages in the amount equal to or greater than \$1,000,000 per occurrence. Env-Wm 1401.10(c) provides that the financial responsibility requirement may be satisfied if the owner is eligible for reimbursement of costs associated with cleanup of releases from the Oil Discharge and Disposal Cleanup Fund (“the Fund”). Eligibility for the Fund is contingent upon achieving and maintaining compliance with statutory (RSA 146-C) and regulatory (Env-

NOTICE OF NON-COMPLIANCE and PERMIT REVOCATION – NCPR # 04-001

January 13, 2004

Page 2 of 3

Wm 1401) requirement. This facility has not achieved compliance, consequently, the Fund is not available to you as a financial responsibility mechanism.

In accordance with RSA 146-C:4 and Env-Wm 1401.07(a), no person shall own or operate an underground storage facility without a permit issued by DES. Within 30 days from the date of the permit revocation the facility shall be closed in accordance with Env-Wm 1401.18 for permanent closure.

Based on the compliance deficiencies described above, DES believes this facility poses a potential substantial threat to the surface and groundwater of the state. Therefore, in accordance with RSA 146-C:4 and Env-Wm 1401.09, if compliance as requested above is not achieved within ninety (90) days of the date of this Notice your Permit-to-Operate (UST Permit #0110674) shall be revoked effective **April 12, 2004**. Within thirty (30) days of the date of permit revocation all regulated substances must be removed from the UST systems at this facility. If the facility achieves compliance during the ninety (90) day period, it is necessary that documentation be submitted to DES verifying that compliance has been attained.

You have the right to a hearing to contest these allegations before the proposed license action is taken. The hearing would be a formal adjudicative proceeding pursuant to RSA 541-A:31, at which you and any witnesses you may call would have the opportunity to present testimony and evidence as to why the proposed action should not be taken. All testimony at the hearing would be under oath and would be subject to cross-examination. If you wish to have a hearing, one will be scheduled promptly.

RSA 541-A:31 III(e) provides that you have the right to have an attorney present to represent yourself at your own expense. If the Permit is an occupational license, under RSA 541-A:31, III(f) you have the right to request DES to provide a certified shorthand court reporter at your own expense. **Such request must be submitted in writing at least 10 days prior to the proceeding.**

You may waive your right to a hearing. If you waive the hearing, DES is prepared to proceed with the actions as stated above. You should notify DES of your decision by filling out and returning the enclosed form.

If there are any questions concerning the above, I may be contacted at the Waste Management Division at (603) 271-1165.

Sincerely,


COPY

Lynn A. Woodard, P.E.

Supervisor

Oil Compliance and Initial Response Section

CERTIFIED MAIL # 7000 1670 0000 0585 1897

cc: Michael P. Nolin, Commissioner
Mark Harbaugh, DES Legal Unit
Fred McGarry, P.E., Chief Engineer, WMD
George Lombardo, P.E., WMD
Tom Beaulieu, WMD
Health Officer, Town of New Hampton